



MADHAV INSTITUTE OF TECHNOLOGY & SCIENCE, GWALIOR

(A Govt. Aided UGC Autonomous & NAAC Accredited Institute Affiliated to RGPV, Bhopal, M.P.)

Gola ka Mandir, Gwalior (M.P.)- 474 005, INDIA

Ph.: +91-751-2409300, Fax: +91-751-2664684, e-mail: director@mitsgwalior.in, website: www.mitsgwalior.in

TESTING / CONSULTANCY REPORT

Civil/MKT/DR/Env.Engg.Lab./TR No. 286/No. To 5843/1179

Date: 09/07/2021

To,
Principal,
Kendriya Vidhyalaya No.-5,
Shastri Nagar,
Gwalior (MP) 474011.



MITS Dispatch

Ref: Your letter No 140118/KV5/Gwalior/24062021 Dated 06.07.2021.

Sub: Testing of Water Sample used for drinking purpose.

Dear Sir,

Please find herewith the test report of the sealed water sample sent by you vide above mentioned reference & subject.

TESTING REPORT

S.No.	Parameters/Tests	Laboratory Results
Physical Parameters :		
1	Temperature	22.4°C
2	Turbidity	Nil NTU
3	Colour	Absent
4	Odour	Un-objectionable
5	Taste	Un-objectionable
Chemical Parameters :		
6	pH Value	8.4
7	Acidity	06 mg/l as CaCO ₃
8	Alkalinity	70 mg/l as CaCO ₃
9	Total Solids	72 mg/l
10	Dissolved Solids	72 mg/l
11	Suspended Solids	Nil mg/l
12	Chlorides	26 mg/l
13	Total Hardness	80 mg/l as CaCO ₃
14	D.O.	5.8 mg/l
Bacteriological Parameters :		
15	MPN/100 ml	Nil

Remarks:

- Testing charges of Rs. 4910/- deposited vide Money Receipt No. 36470 dated 07-07-2021.
- The above tested Parameter of water sample confirms the specification requirement as laid down in IS: 10500-2012 for drinking water. Hence, the water sample found fit for drinking use.
- Sample received on 06-07-2021.
- Testing date/Report generated on: 06-07-2021/08-07-2021.

Prof. I/c PHE Lab & Testing

Testing/Consultancy Amount Paid

Forwarded: Rs. 4910/-

This Testing/Consultancy report is forwarded on the recommendations of the Department. Responsibility of Test/Consultancy Report lies with the concerning department.

Date: 7/7/21

Book No.: MITS TCR/ XXIII

DIRECTOR

Sr. No.: 2020 061

Finance cum Accounts Officer

Head of the Civil Engg. Deptt.